

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 26/-Basic/23-24

Dated: 19/03/24

It is certified that an inspection team headed by ..... Dy. Suman Rai & Team

(Name of Officers with designation) from ..... Jal Kal. Dept Azam PHED

inspected the Modern Era Hr. Sec. School, Jiyampur, Azamgarh UP.

(Name & Address of the school) on 19/03/24 ..... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RWTL/0216/23-24/ ..... dated 16/03/24...

of Regional Water Testing Lab. (PHED Lab) certified that

the Modern Era Hr. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ..... Only 6 month from the date of issue.

Signature with Seal: ..... 19/03/24

Name : Suman Rai

Designation : Dy. Suman Rai

Name & Address of the Office / Department : Jal Kal. Dept Azamgarh UP.

To The Manager, .....

(Name & Address of the Institution)

Modern Era Hr. Sec. School  
Jiyampur, Azamgarh


Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



* TEST REPORT *						
Name & Address of Customer: <b>MODERN ERA HIGHER SECONDARY SCHOOL, JIYANPUR, U.P.</b>			Customer Reference No.		No: 291/sk/27 Dated: 10/03/2024	
			Sample Submitted by		PHOOLA DEVI	
			Date of Sample Receipt		10/03/2024	
			Analysis Starting Date		10/03/2024	
			Analysis completion Date		18/03/2024	
Discipline: Chemical Testing			Group: Water			
Test Report No.:		RWTL/ 0016/23-24		Date of Issue:		19/03/2024
Registration no.:		RWTL/2324/REG2324/0016		Condition of Sample:		Unsealed
Source:		NA		Quantity/Type of Bottle:		1000ml / Amber Colored Glass Bottle
Scheme:		NA		Location/Depth:		RO plant MODERN ERA HIGHER SECONDARY SCHOOL, JIYANPUR, U.P./ NA
Village:		JIYANPUR		Habitation:		NA
Block:-		JIYANPUR		District:		AZAMGARH
Latitude:		NA		Longitude:		NA
Sample Type: Treated Water						
Sr. No	Parameter	Result	As per 15-10500:2012 (2 <sup>nd</sup> Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pFI	7.75	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	280	500	"2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	120	200	600	mg/l	I63025 (Pan 21- 2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	13	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.

  
Dr. Ramesh Yadav  
Quality Manager  
Authorized Signatory  
For, Regional Water Analysis,  
Laboratory Jan Nigam Varanasi – UP.

----- End of the Test Report -----